

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0328:168

Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Potter Electric Signal Co., 2081 Craig Road, St. Louis, MO 63146
Contact: Brad Serangeli (314) 878-4321 Fax (314) 878-7264

DESIGN: Model PFC-7500 and PFC-7501 fire alarm control units. Automatic, manual, noncoded, local, remote station, central station, waterflow and sprinkler supervisory service. Model PFC-7500 does not employ a bell output circuit or 4-wire detector power, it is used for slave applications deriving its power from the host (master) control unit. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PFC-7500, -7501
RA-7692, *-7690

Control Panels
Keypad

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

NOTE: For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1157:104

*Rev. 02-24-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager